



Product Service

# Attestation of Conformity

No. N8A 068988 0106 Rev. 11

**Holder of Certificate:** **Jetion Solar (China) Co., Ltd.**  
No. 1011, Zhencheng Rd.,  
Shengang Industrial District  
214443 Jiangyin  
PEOPLE'S REPUBLIC OF CHINA

**Product:** **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**  
**Mono-Crystalline Silicon Photovoltaic Module**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 704061814810-15

**Date,** 2022-09-09

( Zhulin Zhang )

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

# Attestation of Conformity

No. N8A 068988 0106 Rev. 11

## Model(s):

JTxxxSAh, JTxxxSAh(1500), xxx=350-400, in steps of 5  
 JTxxxSPh, JTxxxSPh(1500), xxx=295-335, in steps of 5  
 JTxxxSGh, JTxxxSGh(1500), xxx=350-415, in steps of 5  
 JTxxxSHh, JTxxxSHh(1500), xxx=295-345, in steps of 5  
 JTxxxSHh, JTxxxSHh(1500), xxx=355-380, in steps of 5  
 JTxxxSGh(1500), xxx=520-550, in steps of 5  
 JTxxxSFh(1500), xxx=480-505, in steps of 5  
 JTxxxSHh(1500), xxx=435-460, in steps of 5  
 JTxxxSEh(1500), xxx=390-415, in steps of 5  
 JTxxxSVh(1500), xxx=435-465, in steps of 5  
 JTxxxSFk, xxx=645-670, in steps of 5  
 JTxxxSHk, xxx=585 to 605, in steps of 5  
 JTxxxSWk, xxx=535 to 555, in steps of 5  
 xxx is standing for rated output power at STC

## Parameters:

Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute, No. 10 West Kaifa Road, Yangzhou, 225009 Jiangsu, P. R. China.
Construction:	Framed, with Junction box, Cable and Connectors.
Safety Class :	Class II
Maximum System Voltage:	1000 V DC or 1500 V DC
Fire Safety Class:	Class C according to UL790.

## Tested according to:

EN IEC 61730-1:2018  
 EN IEC 61730-1:2018/AC:2018-06  
 EN IEC 61730-2:2018  
 EN IEC 61730-2:2018/AC:2018-06

Page 2 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.